

# Ohio Department of Health Public Pool/Spa Data Sheet

ODH file no \_\_\_\_\_

Type of project			Construction type
Outdoor 1. <input type="checkbox"/> Pool 2. <input type="checkbox"/> Spa 3. <input type="checkbox"/> Wading pool 4. <input type="checkbox"/> Diving pool	Indoor 5. <input type="checkbox"/> Pool 6. <input type="checkbox"/> Spa 7. <input type="checkbox"/> Wading pool 8. <input type="checkbox"/> Diving pool	Special 9. <input type="checkbox"/> Special use pool 10. <input type="checkbox"/> Special feature 11. <input type="checkbox"/> _____	1. <input type="checkbox"/> New 2. <input type="checkbox"/> Renovation (See C. of Instructions)

Action governed by  
Ohio Revised Code Chapter 3749

County		Local health district	
Project name		Designer	
Street address		Street address	
City	Township	City	Township
ZIP	Phone ( )	ZIP	Phone ( )
Owner		Contractor	
Street address		Street address	
City	Township	City	Township
ZIP	Phone ( )	ZIP	Phone ( )

**Instructions**

- A. Print clearly
- B. Original and four (4) copies required.
- C. Complete all sections to provide full information. For renovation work always complete section 01; check each section 'New' or 'Existing'.
- D. Where a component is not used or does not exist label that section "N/A"—Not Applicable.
- E. Describe work to be done in Section 14- "Remarks"

<p><b>01. Design Geometry</b></p> <p>a. Pool/Spa surface area _____ ft<sup>2</sup></p> <p>b. Deck surface area _____ ft<sup>2</sup></p> <p>c. Total area _____ ft<sup>2</sup></p> <p>d. Pool Spa volume _____ gal</p> <p>e. Required turnover period</p> <p><input type="checkbox"/> Pool-480 min.    <input type="checkbox"/> Wading pool-120min.</p> <p><input type="checkbox"/> Spa-30 min.    <input type="checkbox"/> Other _____ min.</p> <p>f. Minimum required flow rate (ld / 1e) _____ gpm</p> <p>g. Normal operating flow rate _____ gpm</p> <p>h. Maximum operating flow rate _____ gpm</p> <hr/> <p><b>02. Recirculation Pump</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Make/Model no. _____</p> <p>b. H.P. _____ submit pump curve</p> <p>c. System total dynamic head (usually 40-60ft.) _____ ft.</p> <p>d. Pump capacity (at TDH in 2c) _____ gpm</p> <p>e. Hair/Lint strainer    <input type="checkbox"/> Yes    <input type="checkbox"/> No</p> <p>f. Throttle valve required?    <input type="checkbox"/> Yes    <input type="checkbox"/> No     limit flow _____ gpm</p> <hr/> <p><b>03. Other Pumps</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Make/Model no. _____</p> <p>b. H.P. _____ submit pump curve</p> <p>c. System total dynamic head (usually 40-60ft.) _____ ft.</p> <p>d. Pump capacity (at TDH in 3c) _____ gpm</p> <p>e. Throttle valve required?    <input type="checkbox"/> Yes    <input type="checkbox"/> No     limit flow _____ gpm</p>	<p>f. Flow measuring device _____     Range _____</p> <p><b>Note:</b> Provide vertical loop (12 inch minimum above top of pool) for air blower to prevent shock hazard.</p> <hr/> <p><b>04. Filtration</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Filter type    <input type="checkbox"/> Sand    <input type="checkbox"/> D.E.    <input type="checkbox"/> Cartridge                     <input type="checkbox"/> Pressure    <input type="checkbox"/> Vacuum</p> <p>b. Make/Model no. _____</p> <p>c. Number    Elements _____ Filters _____</p> <p>d. Area of each    Elements _____ Filters _____</p> <p>e. Total filter area _____ sf</p> <p>f. Commercial filter design flow rate _____ gpm/sf</p> <p>g. Maximum allowable filter flow (4e x 4f) _____ gpm</p> <hr/> <p><b>05. Main Drain</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Anti-Vortex grates    <input type="checkbox"/> Yes    <input type="checkbox"/> No</p> <p>b. Make/Model no. _____</p> <p>c. Size/Dimension _____ in</p> <p>d. Each grate open area _____ sq-in</p> <p>e. Velocity thru grate at 100% of 2d _____ fps</p> <p>f. Maximum allowable flowrate _____ gpm</p> <hr/> <p><b>06. Other Suction Drains</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Anti-Vortex grates    <input type="checkbox"/> Yes    <input type="checkbox"/> No</p> <p>b. Make/Model no. _____</p> <p>c. Size/Dimension _____ in</p> <p>d. Each grate open area _____ sq-in</p> <p>e. Velocity thru grate at 100% of 3d _____ fps</p> <p>f. Maximum allowable flowrate _____ gpm</p>	<p><b>07. Overflow</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Skimmers</p> <p>1. Make/Model no. _____</p> <p>2. Number _____</p> <p>3. Equalizer (equalizer valve required)</p> <p>    a.) Depth below operating level _____ in.</p> <p>b. Gutters</p> <p>1. Make/Model no. _____</p> <p>2. Number of drain/collector boxes _____</p> <p>3. Open area each box _____</p> <p>4. Number of return boxes _____</p> <p>5. Available surge capacity (gallons)</p> <p>    Surge tank _____</p> <p>    Pool _____</p> <p>    Gutters _____</p> <p>    Total _____</p> <hr/> <p><b>08. Return Inlets</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. <input type="checkbox"/> Wall    <input type="checkbox"/> Integral gutter</p> <p>1. Depth below operating level _____ in.</p> <p>2. Spacing _____ #</p> <p>b. Floor (space uniformly) _____ #</p> <hr/> <p><b>09. Piping</b>    <input type="checkbox"/> New    <input type="checkbox"/> Existing</p> <p>a. Type Material _____</p> <p>b. Schedule or S.D.R. no. _____</p> <p>c. A.S.T.M. no. _____</p> <p>d. Other _____</p> <p><b>Note:</b> All pipe shall be clearly labeled.</p>
--	--	--

**10. Chemical Feeders**  New  Existing

a. Disinfection feed system(s)

1. Hypochlorite  Calcium  Sodium

2. Erosion  DiTri-Chloro  Bromine

3. Make/Model no. \_\_\_\_\_

4. Dosing rate  gpd  lbs. per day  
 minimum \_\_\_\_\_ maximum \_\_\_\_\_

b. Other chemical feed system(s)

1. Reagent \_\_\_\_\_ concentration \_\_\_\_\_

2. Make/Model no. \_\_\_\_\_

3. Dosing rate  gpd  lbs. per day  
 minimum \_\_\_\_\_ maximum \_\_\_\_\_

c. Automatic chemical controller (shall be installed on all new spas)

1. Make/Model no. \_\_\_\_\_

2. Provides proportional dosing rate  Yes  No

3. Reagent feeders  disinfection  ph

**Note:** Unit shall measure ORP and operate only when there is recirculation flow.

**11. Make-Up/Fill Water/Waste Water**  New  Existing

a. Water supply from approved source  Yes  No

b. Backflow/cross connection protection

1. Fill spout with proper air gap  Yes  No

2. Hose bibb w/ASSE backflow prevention valve  Yes  No

3. Direct connection from supply to recirculation system w/backflow prevention valve  Yes  No

a.) Make/Model no. \_\_\_\_\_

b.) ASSE no. \_\_\_\_\_

**Note:** Show filter backwash and/or pool drainage discharge line on plans.

**12. Monitoring Devices**  New  Existing

a. Flowmeter—Make/Model no. \_\_\_\_\_  
 Range \_\_\_\_\_

b. Press/Vac Gauge—Make/Model no. \_\_\_\_\_  
 Range \_\_\_\_\_

**Note:** Monitoring devices shall be correctly sized for the pipe diameter, flow, proper range, and shall be installed on straight pipe at least 10 pipe diameter downstream and 5 pipe diameter upstream from any fitting.

**13. Miscellaneous (check appropriate boxes)**

a. Lighting:  outdoor pool w/night use  indoor pool

1. Water surface  with underwater lighting;  $\geq 30$  fc area lighting  
 without underwater lighting;  $\geq 50$  fc area lighting

**Note:** underwater lighting  $\geq 2.5$  watts/sf (pool surface area)

2. Deck level  $\geq 50$  fc (required deck area)

b. Pool and/or wading pool fence/barrier

1. Perimeter enclosure  $\geq 48$  in high

2. Wading pool barrier between pool(s)  $\geq 36$  in high

3. Four inch diameter sphere shall not pass through any opening

4. Gates/doors shall be lockable (except wading pool barrier) self-closing, and self-latching

c. Deck markings/warnings signs\*

1. Depth markers on deck per code

2. "No Diving" signs on deck per. code

3. "Warning, No Lifeguard" signs per code

4. Cautionary sign for spa users posted

5. Sign with location of nearest telephone posted

6. Emergency phone numbers posted

7. Other \_\_\_\_\_

d. Deck fixtures

1. Diving boards  Competitive  Recreational  
 standard used for design \_\_\_\_\_

2. Starting blocks

3. Water slides

4. Steps, ladders, handrails

5. Handicap ramps

6. Life guard chair(s) # \_\_\_\_\_

7. Other \_\_\_\_\_

e. Safety—Equipment\*

1. First aid kit

2. Emergency telephone available

3. Reach poles

4. Ring buoy(s) with throw line

5. Spine board

6. Rescue tube(s) (one per guard chair)

7. Other \_\_\_\_\_

\*Provide signs and safety equipment prior to licensure by local health department.

- Note:**
- Filters, primary disinfection devices, or skimmers shall be of an approved type. (NSF, ETL or as approved by the Director).
  - Spa heater must be thermostatically controlled to a maximum of 104°F.
  - All electrical must conform to Article 680 of the current National Electric Code
  - All equipment and materials associated with the pool are subject to approval by the Ohio Department of Health.
  - Ventilation for filter rooms and indoor pools must be adequate to remove excess condensation, prevent fungal growth, and remove noxious odors/gases.
  - Heat exchangers for boiler coils must be of double wall construction.

**14. Remarks**

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

This Data Sheet when approved becomes a binding part of the plans. Individuals to be contacted for questions regarding this proposal (please print).

Name	Phone
_____	( )

I certify the above information has been approved by the owner and is a true representation of the facts and the project as it is to be constructed.

Designer	Phone
_____	( )

Contact Environmental Engineering for any questions concerning this form.  
 Ohio Department of Health, Bureau of Environmental Health, 246 North High Street, Columbus, Ohio 43215-2412. (614) 466-1390  
 Projects submitted without this form are incomplete and will not be reviewed.