

## Acceptable Automatic Pool Chemical Controllers

The automatic chemical controller units listed below have been reviewed and approved by the Ohio Department of Health (ODH) in accordance with Ohio Administrative Code (OAC) 3701-31-04(D)(7). This rule sets forth minimum functional requirements for automatic chemical controllers whether they are installed on public spas, public swimming pools, special features or spraygrounds. This requirement became effective January 1, 1999 with the specifications for these units modified in April 2011 to require the monitoring and display of both pH and oxidation-reduction potential (ORP). According to OAC 3701-31-02(G)(3) the director shall maintain a list of controllers that meet these requirements. **This is not a comprehensive list.** If a unit is not on this list but meets the specifications of 3701-31-04(D)(7)(a) through 3701-31-04(D)(7)(d), the operator may submit the unit for review. Please contact the public swimming program at (614)644-7438 for information on the submittal process.

<u>Manufacturer</u>	<u>Unit</u>			
<b>AquaCal AutoPilot, Inc.</b> 5841 Powerline Road Ft. Lauderdale, FL 33309	Pool Pilot Total Control complete with acid feeder and pH			
<b>Aquasol Controllers, Inc.</b> 1707 Townhurst Dr. Houston, TX 77043	Aquasol Controller Models	WTC	XPC	
<b>BECS Technology</b> 9487 Dielman Rock Island Ind. Dr. Saint Louis, MO 63132	BECS Technology Models	BECSys2 BECSys3	BECSys5 BECSys7	
<b>Chemtrol</b> 5375 Overpass Road Santa Barbara, CA 93111	Chemtrol Models	250 PC2000 PC2100	PC3000 PC5000 PC5100	PC6000 PC7000 PC7100
<b>ControlOMatic, Inc.</b> 12659 Arbor Lane Grass Valley, CA 95949	ControlOMatic Models	MiniWarden PoolWarden D PoolWarden S		
<b>Ecolab Inc.</b> 655 Lone Oak Drive Building F, Floor 6 Eagan, MN 55121	Ecolab Inc. Models	AK2100-D AK2100-S		
<b>Hayward Commercial Pool Products</b> 10101 Molecular Drive #200 Rockville, MD 20850	Hayward CAT Controllers Model	CAT 2000 CAT 4000 CAT 5000 HCC2000 HCC2000-CP		
<b>IPS Controllers</b> 2611 Ynez Road, Suite C-4 Temecula, CA 92591	IPC Controller Models	M790 M820 M920		
<b>National Aquatics Distributors, Inc.</b> 24551 Production Cr. Unit #2 Bonita Springs, FL 34135	Siemens Strantrol model	Set Point NX Compact Pool		
<b>Pentair Aquatic Systems</b> 10951 West Los Angeles Ave. Moorpark, CA 93012	Pentair models	IntelliChem PN 521357 AcuTrol AK110PD-CD		
<b>ProMinent Fluid Controls</b> 136 Industry Drive Pittsburgh, PA 15275	ProMinent Controllers Series	DCM 2 DCM 5		

## Acceptable Automatic Pool Chemical Controllers

<b>Pulsafeeder, SPO</b> 27101 Airport Road Punta Gorda, FL 33982	Pulsablue model	#C3313 with the pH option
<b>Rola-Chem Corp.</b> 5858 Centerville Road St. Paul, MN 55127	Rola-Chem Corp. models	RC554XXP – Dual ORP / pH Controller  RC554XP – ORP / pH Controller
<b>Zodiac Pool Systems, Inc.</b> 2620 Commerce Way Vista, CA 92081-8438	Polaris Watermatic Controller Models	C2000 C660
<b>H.W. Rhodes Inc.</b> 5511 Brampton Road Dayton, OH 45429	Chemcon Model 12 HWR Model 12	
<b>TMI Sustainable Aquatics</b> P.O. Box 433 Manchester, WA 98353	EMCD-i RSC-1 Series RSC-3 Series	